



# Ηλιακή Ψύξη και Εξοικονόμηση Ενέργειας στη Γεωπονική Σχολή του Πανεπιστημίου της Άγκυρας στην Τουρκία

Δρ Ελευθερία Αλεξανδρή

SOLARBUILD, Αθήνα, 13.12.2007

# Solar cooling and energy savings in the University of Ankara, in the context of Hellenic Aid

Within WP1 “*Installation and Operation of the Solar Air-conditioning System in buildings in the University of Ankara*” in the project “*Action Plan Development for the Reinforcement of Cooperation with Turkey in the Field of Renewable Energy Sources*”, under the funding of **Hellenic Aid 2006**, RES and energy saving actions will take place in buildings of the **Farm Machinery Department, School of Agriculture**, encouraging scientific interaction and the development of business collaboration in the RES field between the two countries.



# The role of **HELLENIC AID**

MINISTRY OF FOREIGN  
AFFAIRS OF GREECE




The Hellenic International Development Cooperation Department Hellenic Aid was established in 1999 in the Ministry of Foreign Affairs of Greece, and is mainly responsible for the supervision, coordination, monitoring and promotion of emergency humanitarian aid actions, as well as aid for the reorganisation and restoration of the infrastructures of developing countries. Within the latter, it has promoted actions of **Renewable Energy and Energy Saving Applications**.



# Project's object – existing situation

Office buildings with lecture rooms and laboratories in the Farm Machinery Department of the School of Agriculture.




Buildings where energy upgrade will take place

The  
no  
So  
in  
An  
27  
an  
emissions.

with concrete beams and  
er  
a  
y p  
with gas, while there is

or  
c  
is  
d

# Climatic Data – Solar Potential




Data derived from the University of Ankara

- Maximum solar radiation in July, with average solar radiation on a horizontal plane 202KWh/m<sup>2</sup> (min 165 KWh/m<sup>2</sup> in 1990 and max 228KWh/m<sup>2</sup> in 2003)

Minimum solar radiation in December, with average solar radiation on a horizontal 42 KWh/m<sup>2</sup>. (min 30 KWh/m<sup>2</sup>, in 1992 and max 51 KWh/m<sup>2</sup> in 2004).

- The duration of the sunlight reaches 344 hours in July, while it lowers to only 69 hours in December.

# Climatic Data – Hydrothermal Data



**Steppe climate** (semi-arid), with dry season in summer (warm and dry summers) and cold winters with snow


Air temperature in summer: 24.0°C with average maximum 36.0°C (*max 41.0°C in 2000*)

Air temperature in winter: 0.8°C with average minimum -10.0°C (*min -21.5°C in 1985*)

Relative humidity from 48% in summer to 77% in December

# Energy upgrading scenarios; Only solar cooling

Absorption cooling is applied, with 35KW nominal power of absorption cooler and 160m<sup>2</sup> solar collectors.



Heating energy savings: only **14%**  
for heating only building B


Cooling energy savings: **93%** for  
offices of the 1<sup>st</sup> and 2<sup>nd</sup> floor of  
building B

Not reducing significantly the  
energy demand and the CO<sub>2</sub>  
emissions of the building.


With the cost of solar cooling  
installation (~140,000€), this is not  
a profitable installation on its own.

# Energy upgrading scenarios; thermal insulation

- Scenario [1]: **Thermal insulation of the roofs only**  
 Heating energy savings: **9%** for both buildings B & D  
 Cooling energy savings: **25%** for offices of the 1<sup>st</sup> and 2<sup>nd</sup> floor  
 Annual CO<sub>2</sub> emissions: **159tn**



- Scenario [2]: **Thermal insulation of both roofs and walls**  
 Heating energy savings: **54%** for both buildings B & D  
 (*specific space heating energy 137 KWh/m<sup>2</sup>*)  
 Cooling energy savings: **28%** for offices of the 1<sup>st</sup> and 2<sup>nd</sup> floor  
 Annual CO<sub>2</sub> emissions: **87tn**





# Energy upgrading scenarios; thermal insulation & external shading devices

External shading devices are placed in the places that need cooling; in the South-oriented offices of building B & D.

- Scenario [3]: **Thermal insulation of both roofs and walls & external shading devices**

Heating energy savings: **54%** for both buildings B & D

Cooling energy savings: **67%** for offices of the 1<sup>st</sup> and 2<sup>nd</sup> floor


Annual CO<sub>2</sub> emissions: **68tn**

- Scenario [3+]: **Thermal insulation of both roofs and walls & external shading devices + night cooling of offices**

Heating energy savings: **54%** for both buildings B & D

Cooling energy savings: **69%** for offices

Annual CO<sub>2</sub> emissions: **67tn**



# Energy upgrading scenarios; thermal insulation, external shading devices & solar cooling

- Solar cooling is placed in the offices of the 1<sup>st</sup> and 2<sup>nd</sup> floor of building B (cost ~140,000 €)
- External shading devices are placed on the South-oriented openings of the offices of the 1<sup>st</sup> and 2<sup>nd</sup> floors of buildings B and D (cost ~15,000 €)
- External wall insulation and roof insulation is placed on both buildings B and D (cost ~55,000 €)


Heating energy savings: **65%** for both buildings B & D

Cooling energy savings: **84%** for offices of the 1<sup>st</sup> and 2<sup>nd</sup> floor

Annual CO<sub>2</sub> emissions: **51tn**

(**70%** decrease of annual CO<sub>2</sub> emissions)

~12,500 € annual savings from energy bills



# Conclusions



- Expensive technologies such as solar cooling are not adequate on their own to offer large energy saving for uninsulated buildings in the geographical latitudes of the Mediterranean.
- Thermal insulation and external shading devices can offer large energy savings for heating and cooling.
- The combination of energy saving applications and solar cooling is capable of decreasing considerably the building needs in auxiliary heating and thus its CO<sub>2</sub> emissions.